

Addendum No. 1

ITB No. 16-06: Gasboy Upgrade

February 9, 2016

ITB #16-06 is hereby amended as follows:

1. Below are questions received and corresponding answers:

- A. Question: Item #10 – Replacing conduits. I am assuming that item #10 is the cost to replace the electrical conduits for the Gasboy system only. Please clarify.

Answer: Yes, only in the event the existing conduit is not usable.

- B. Question: Item #12 – Replace fuel dispensers. Your existing Gasboy fuel dispensers have mechanical registration. Do you want Mecco to bid dispensers with Mechanical registration or are we to bid dispensers with Electronic display. Electronic dispensers will require that we pull additional electrical conductors. Please clarify.

Answer: As it stands we plan to go with the mechanical dispensers. If you could give us the cost of the electronic dispensers as an option please do so.

- C. Question: Item #13 – Replace electrical wiring & conduits for installation. Does this line item cost for electrical conduits and wiring for the fuel dispensers only? Please clarify.


Answer: Yes, only in the event the existing conduit is not usable.

- D. Question: Item #14 – Replacing Veeder-Root TLS-350 console. Are we to figure replacing the console only or the cost to replace the complete system which would include probes and any associated sensors? Also, if this is the cost to just replace the console what model console are we to quote going back with the TLS-350 plus console or the TLS-450 plus console? Please clarify.

Answer: It is my understanding that the console we currently have is compatible with the software upgrade. If not please advise.

Board of Commissioners

Richard A. Oden, Chairman
Oz Nesbitt, Sr., Commissioner
Dr. Doreen Williams, Commissioner



Department of Finance

Telephone: 770-278-7555
Facsimile: 770-278-8910

2. All other conditions remain in full force and effect.
3. If a proposal has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the proposal price, the new price and/or changes will be inserted below:

4. All bidders under this Invitation to Bid are kindly requested to acknowledge receipt of this Addendum on Page 13, Part II of the Bid Form.

Tina Malone

Tina Malone, CPPB CPPO
Procurement Officer
Department of Finance, Purchasing Division